

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 4

General Comments

Group Care Inspection
Dalia Villar (Principal) signed the inspection.
Yulicel Valdes (Secretary), assisted with the inspection.
Shower head: N/A: Public Elementary School.

Email Address(es): daliavillar@dadeschools.net;
255812@dadeschools.net;
gracie@dadeschools.net;
ipalacio@dadeschools.net;
wcabrera@dadeschools.net;
mwertz@dadeschools.net;

Inspector Signature:

Handwritten signature of the inspector.

Client Signature:

Handwritten signature of the client.

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



3 of 4

Violations Comments

Violation #5. Maintenance & Repair

Observations:

Stains on Ceiling Panels:

1. Room # 001 (one (1) stained ceiling panel).
2. Room # 013 (one (1) stained ceiling panel).
3. Room # 010 (six (6) stained ceiling panels).
4. Room # 006 (four (4) stained ceiling panels).
5. Room # 011 (eleven (11) stained ceiling panels).

Replace all stained ceiling panels in each room.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #6. Lighting Standards

Observations:

Burnt-Out Light' Bulbs in Lamps:

1. Room # 001 (one (1) Lamp with one (1) burnt-out light bulb: FC: 15.59).
2. Room # 013 (one (1) Lamp with one (1) burnt-out light bulb: FC: 11.93).

Replace all burn-out light bulbs in each Lamp.

CODE REFERENCE: 6. Lighting Standards. 468.3.2. FBC. Sources of natural light in instructional spaces shall be glazed with glare reducing materials or shall be shielded to prevent glare that can interfere with seeing task.

Inspector Signature:

Handwritten signature of the inspector.

Client Signature:

Handwritten signature of the client.

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



4 of 4

Inspection Conducted By: Alberto Reyes (032763)
Inspector Contact Number: Work: (305) 623-3500 ex.
Print Client Name: Dalia Villar (Principal).
Date: 6/1/2026

Inspector Signature:

Handwritten signature of Alberto Reyes.

Client Signature:

Handwritten signature of Dalia Villar.